

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0694:219 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire Control Instruments, *16 Southwest Park, Westwood MA 02090
Contact: Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

DESIGN: Models 7100-1, 7100-2, 7100-1D and 7100-2D fire alarm control units. Power-limited; non-coded, manual, automatic, local, auxiliary, central station, remote station, proprietary service, releasing device service, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

BSM-1	1120-0783	Basic System Module
BSM-2	1120-0781	Basic System Module
BSM-1D	1120-0782	Basic System Module with DACT
BSD-2D	1120-0780	Basic System Module with DACT
CAOM	1120-0763	Class A Option Module
MCOM	1120-0761	Municipal Module
PTRM	1120-0762	Printer Module
7100-EN-M-Door	1120-0779	Metal Door
7100-EN-Back Box	1120-0787	Back Box
7100-EN	1120-0787	Enclosure
7100-TXA	1120-0778	Transformer Assembly
7100-EN-P-Door	1120-0779	Plastic Door
7100-TXA-240	1120-0801	240V Transformer Assembly
INI-7100	INI-7100-UTP/-FO	Intelligent Network Interface

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Inc. Label

APPROVAL: Listed as fire alarm control units for use with separately listed electrically compatible initiating and indicating devices.

These control units can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to listee's Installation Instructions Manual for details.

NOTE: For **Fire Alarm Verification Feature** (delay of fire alarm), the maximum Retard/Rest/Restart period shall not exceed 30 seconds.

*Rev. 02-05-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager